




ANNUAL ASBESTOS MANAGEMENT NOTIFICATION

September 27, 2021

Dear Staff, Guardians and Students:

Copies of the Hillcrest Educational Centers, Inc. Asbestos Management Plans are available at each site and are available for review during regular business hours. Any inquiries to review the Asbestos Management Plans should be directed to our AHERA designated person, Patrick Prendergast, by email as follows:

patp@hillcresteducationalcenters.org

Signature: 
(Patrick Prendergast)

9/24/21

Notification of asbestos remediation and sampling of building materials 2021

Hillcrest Educational Centers has conducted some Asbestos Remediation and building materials sampling this calendar year 2021, at the Hillcrest Academy located at 400 Columbus Ave. Pittsfield MA.

Sampling that was done on 1/8/21 of suspect material (wood adhesive) on interior classroom doors proved to be **negative** for the presence of asbestos. The sampling report is in the management plans.

July 22 2021 classrooms 106,107,109 and 210 had broken exterior windows replaced after the asbestos containing caulk was removed by Barile Environmental. The documentation (permit, air clearances, waste shipment manifest) are located on site in the Asbestos Management Plans.

8/20/2021 plaster on the walls of the gymnasium were sampled and found to be **negative** for asbestos. Also on that date, caulking around observation windows of the classrooms was sampled and also resulted in a **negative** for asbestos finding.

9/16/21 glue for tiles on a 1st floor bathroom was tested and found to be **positive** for asbestos. An remediation process is underway.

9/7/2021 Hillcrest Center ASD campus had some asbestos plaster removed from the basement boiler room ceiling. This material had previously tested **positive** for asbestos. All documentation is at the Center Campus management plans.

Patrick Prendergast

Asbestos Coordinator