


CHECKING IRT/C AMBIENT TEMPERATURE

The IRT/c is designed and manufactured to provide a lifetime of reliable operation in the most demanding service conditions. To assure this performance, every IRT/c is put through a rigorous process of manufacture, including seven separate test stages. At the end of this process, the IRT/c is ready to be installed, and is ready to provide you with reliable infrared temperature data for many years.

As an additional reliability feature, all IRT/c's are manufactured with a Xenon gas fill hermetically sealed into the sensing system. If the hermetic seal is broken by mechanical or thermal damage to the sensor, the Xenon immediately escapes, and the IRT/c radiation sensitivity (difference

between target and sensor temperature) immediately drops by more than a factor of two, thus providing an obvious indication of failure, rather than a gradual change which can cause poor quality service for a long period of time before a failure is detected.



Exergen Global offices:

The Netherlands
Pastoor Clercxstraat 26
5465 RH Veghel
Tel: +31(0) 413 37 65 99
Fax: +31(0) 413 37 93 10

USA
400 Pleasant Street
Watertown, MA 02472
Tel: +1 617 649 6322
Fax: +1 617 923 9911

office@exergenglobal.com
www.exergenglobal.com