



LOGANVILLE FIRE AND EMERGENCY SERVICES

Office of the Fire Marshal
4303 Lawrenceville Road
Loganville, Georgia 30052
kdurden@loganville-ga.gov
Office (770) 554-9693 Fax (770) 554-6565

Existing Building Inspection

The Loganville Fire Marshal's Office is required to perform maintenance inspection in existing buildings. The following is a *general list* of items that will be inspected, in order to insure all Life Safety and Fire Codes adopted by Loganville Fire Services are maintained in existing buildings.

This inspection may not be limited to the items listed below, depending upon the occupancy type. These items must be maintained in order to pass the inspection.

1. If the building has a Sprinkler system, a copy of a current (within 1 year) annual sprinkler test certification report shall be provided to the Fire Inspector upon request.
2. If the building has a Fire Alarm system, a copy of a current (within 1 year) annual Fire Alarm test certification report shall be provided to the Fire Inspector upon request.
3. If the building has a Hood Suppression system, it shall be inspected and serviced every six months by a state licensed company. The system shall bear a yellow inspection tag. The hood, ductwork, fan and filters shall be cleaned by a certified hood cleaning service. Provide a copy of an invoice from that company to the Fire Inspector. Also provide a letter from a license HVAC contractor that the hood and exhaust system meet all applicable codes and is in proper working order.
4. All Exits shall be clear and unobstructed.
5. All Doors, door swings, door closers, door hardware, and force to open doors shall be maintained in proper working order.
6. In multi-story buildings with Stairs, all Stairs shall all be maintained and unobstructed. No combustible storage is allowed under stairs.
7. All Emergency and Exit Lighting shall be maintained in working order. These lights shall operate on normal electrical power and on battery back up power. Exception: buildings provided with an emergency backup generator.
8. Smoke and Duct Detectors shall be maintained in proper working condition.

9. All Fire Extinguishers shall be maintained by a State of Georgia licensed Fire Extinguisher company and shall have a current inspection tag signed and dated by them. **Loganville Fire Inspectors do not perform maintenance procedures on Fire Extinguishers.**
10. Storage of any Hazardous Materials as defined by the Fire Code shall be permitted by the Loganville Fire Marshal's Office and stored properly.
11. Storage of materials near Electrical Panels and/or Mechanical Equipment shall be a minimum of 30 inches from the equipment.
12. Extension cords are allowed on a temporary basis only. Temporary is **defined as not more than 30 days.**
13. All Interior Finishes required by the Life Safety Code shall be maintained.
14. All Storage and Housekeeping Practices shall be kept in neat order and cleanly maintained.
15. Occupant load signs shall be maintained and clearly visible in the areas for which they apply. (If required)
16. All Accessibility features shall be maintained properly and in accordance with the Georgia Accessibility Code. (i.e., vehicle parking, access to the building, restrooms, shower, water fountains, telephones, etc.)
17. Fire Hydrants and Fire Department Connections must be free and clear of obstructions and in proper working order.
18. In a tenant space, ceiling tiles shall be removed in a manner suitable for the Fire Inspector to thoroughly inspect existing tenant demising walls. (A ladder may be requested by the Fire Inspector for his inspection.)