

CONSUMER CONFIDENCE REPORT 2020

The City of Loganville is committed to providing quality water to our customers. The Walton County Water Department (WCWD) and Gwinnett County supply the City of Loganville with high quality drinking water. The following data will explain where your water comes from and the treatment processes that are used.

Where does my water come from? The primary source of water supply for the WCWD is the Lake Varner Reservoir and Treatment Facility located in Newton County. The WCWD is a 25% partner of the Lake Varner facilities. The WCWD also purchases additional water supply from neighboring utility systems including Oconee County (Bear Creek Reservoir), the City of Monroe (Alcovy River/John Briscoe Reservoir), and Gwinnett County (Lake Lanier).

The water we drink is withdrawn from sources mentioned above, and processed through a water treatment facility to meet Federal Drinking Water Standards. Potassium Permanganate may be fed into the raw water for Manganese and Iron control. The water is then treated to remove several contaminants. Chlorine and Chlorine Dioxide are also used for viruses and bacteria that may be present in raw water. Fluoride is added to enhance dental protection. Phosphate and hydrated lime are commonly used for corrosion control.

Contaminants that may be present in source water before treatment include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic tanks, agricultural livestock and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic production wastewater discharges, oil and gas production, mining and farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture and residential use.
- Radioactive contaminants, which may be naturally occurring.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems.

REGULATED CONTAMINANTS							
Substance	MCL (MRDL)	MCLG (MRDLG)	Loganville Water System Maximum	Detected Range	Is The Water Safe?	Year Tested	Typical Source of Contaminant
MICROBIOLOGICAL CONTAMINANTS							
Filtered Turbidity	TT = 0.3 NTU % Samples < 0.3 NTU	0 100%	0.17 NTU	0.00 - 0.23 NTU	Yes	2020	Agriculture, Geology
Total Coliform Bacteria	5% of Samples Positive	0% Positive	0% Positive	0% Positive	Yes	2020	Naturally Occurring
Total Organic Carbon	TT	N/A	2.77 ppm	0.50 - 2.17 ppm	Yes	2020	Naturally Occurring
DISINFECTION & DISINFECTION BY-PRODUCTS							
Total Trihalomethanes	80 ppb	N/A	AA 34.3 ppb*	8.01 - 10.6 ppb	Yes	2020	Treatment Process By-Product
Haloacetic Acid	60 ppb	N/A	AA 29.1 ppb*	4.18 - 5.36 ppb	Yes	2020	Treatment Process By-Product
Chlorine	4 ppm	4 ppm	1.42 ppm	0.72 - 2.27 ppm	Yes	2020	Water additive used to control microbes
INORGANIC CONTAMINANTS							
Fluoride	4 ppm	4 ppm	1.11 ppm	0.14 - 1.08 ppm	Yes	2020	Water additives which promotes strong teeth
Nitrate	10 ppm	10 ppm	0.52 ppm	.00 - .52 ppm	Yes	2020	Erosion of natural deposits
Substance	Action Level	MCLG	Loganville Water System 99th Percentile	# of Samples Above Action Level	Water Safe?	Year Tested	Typical Source of Contaminant
Copper	1300 ppm	1300 ppm	120 ppm	0	Yes	2019	Household Piping
Lead	15 ppb	0 ppb	3.7 ppb	1	Yes	2019	Household Piping

Water Quality Sampling: The Loganville Water staff conducts routine sampling throughout the system in accordance with regulatory agencies. These tests ensure that the proper chemical levels are maintained and that the water remains free of unwanted contaminants.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases radioactive materials and can pick up substances resulting from the presence of animal or human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

Water Conservation: You can play a role in conserving water and save yourself money in the process by becoming conscious of the amount of water your household is using and by looking for ways to use less whenever you can. Check faucets, toilets, service lines, etc. for leaks on a regular basis. A small toilet leak can consume more than 30,000 gallons of water per year. A good way to identify leaks is to look at your water meter outside. If the triangular indicator is moving when no water is being used inside, you have a leak in your water system. A licensed plumber can assist in identifying and repairing the leak. If you observe an apparent water leak in your yard on your street, please contact Loganville Water Department immediately for further investigation and repair. Other water conservation tips can be found at www.conservewatergerogia.net

Important Health Information: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA / CDC guidelines on appropriate means to lessen the risk of infections by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

Lead and Drinking Water: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at <http://epa.gov/safewater/lead>.

The Loganville City Council meets the second Thursday of each month at 6:30 p.m. in the Council Chambers, located at 4303 Lawrenceville Highway (City Hall). Please feel free to attend these meetings. For additional information about your water, contact Chris Taylor at 770-466-0911 or 770-466-1306.