



25-09-2020

Summary of Anti-slip properties of SofSurfaces floor covering.

Tests have been performed by TCKI from The Netherlands, RvA ISO EN-17025 accredited.  
Full reports available on request.

#### **SofSurfaces Plus Serie tiles**

Pendulum test EN 14904 : PTV = 91  
Tribometer test NEN 7909 : Dry  $\geq$  0.51  
: Wet  $\geq$  0.29  
Rating for shot feet : Dry : R 11  
: Wet : R 10

#### **SofSurfaces Plus XT Serie tiles**

Pendulum test EN 14904 : PTV = 91  
Tribometer test NEN 7909 : Dry  $\geq$  0.29  
: Wet  $\geq$  0.24  
Rating for shot feet : Dry : R 10  
: Wet : R 10

#### **SofSurfaces Premium Serie tiles**

Pendulum test EN 14904 : PTV = 111  
Tribometer test NEN 7909 : Dry  $\geq$  0.44  
: Wet  $\geq$  0.30  
Rating for shot feet : Dry : R 11  
: Wet : R 10