



Whitley County Health Dept Community Environmental Rating Report

Today's Date 10-11-18 Report for Collamer (27 residences w/ SR 14)

of non-compliant systems - determined as % 56% 15 of 27

of citations = determined as a % 7% , 2 complaints, 3 repairs

Information received from community None

Physical site assessment This town is bordered on the South by the Eel River.

Those non-compliant septic discharge directly or through a stream to the river.

Prior testing data none. I have been witness to septic effluent in the stream by
falling in and then recognizing the odor of effluent.

Written Summary: Very old community that has existed this way for a hundred
years. Over half discharge off site and directly to State waters.

Overall Assessed Score (1-5): 1