



Whitley County Regional Water & Sewer District  
220 W Van Buren St. Suite 101  
Columbia City, IN 46725  
E-mail: SewerDistrict@whitleygov.com

## Whitley County Health Dept Community Environmental Rating Report

Today's Date 10-11-18 Report for Laud (44 Residences ±)

#of non-compliant systems - determined as % 93%, 41 of the 44

# of citations = determined as a % 1 written complaint for sewage

Information received from community Most homeowners do not know of their septic.

However, previous inspections of properties revealed the tiling of house to the the open ditch to the south.

Physical site assessment This septic issue has been known for years by the County

and the State Dept. of HHealth. Due to its location, viable solutions have not been found.

Prior testing data none

Written Summary: It is well known that the houses drain to the center tile that runs north and south in the town, then to the open ditch. I have witnessed persons repairing their tiles that go to the center tile. All of the homes but 3 discharge to waters of Indiana.

Overall Assessed Score (1-5):     /