



Whitley County Health Dept Community Environmental Rating Report

Today's Date 10-11-18 Report for Churubusco - West Side (36 residences)

of non-compliant systems - determined as % 50% non compliant (18 homes)

of citations = determined as a % 0%, no written complaints

Information received from community This subdivision was built prior to the health department existence. Most of the systems discharge off site.

Physical site assessment 5 repairs have been completed over the years. Lots are too small for septic improvement. Most homes drain off site to the Northwest to a county tile.

Prior testing data No water or dye testing has been performed. Most homeowners do not know where their septic is located.

Written Summary: Most of the home septic are illegal, discharging off the lot.
Many unauthorized repairs have been made over the years to create and continue the off site discharge.

Overall Assessed Score (1-5): 1